

## Appendix D

### Cold Water Inlet Temperatures for Selected U.S. Locations

Location	Avg. Cold Water Inlet Temperature (° F)	Location	Avg. Cold Water Inlet Temperature (° F)	Location	Avg. Cold Water Inlet Temperature (° F)
Anchorage, AK	38.6	Boston, MA	59.3	Rochester, NY	57.0
Birmingham, AL	71.7	Baltimore, MD	56.8	Rome, NY	51.3
Montgomery, AL	66.4	Portland, ME	63.5	Syracuse, NY	54.7
Little Rock, AR	63.9	Detroit, MI	49.9	Watertown, NY	51.7
Phoenix, AZ	82.3	Minneapolis, MN	45.8	Columbus, HO	54.8
Los Angeles, CA	72.8	Kansas, City, MO	51.1	Oklahoma City, OK	58.8
San Diego, CA	76.2	St. Louis, MO	61.3	Portland, OR	51.6
San Francisco, CA	67.7	Biloxi, MS	64.9	Philadelphia, PA	56.0
Denver, CO	61.3	Jackson, MS	67.8	Pittsburgh, PA	58.0
Hartfort, CT	56.6	Helena, MT	41.8	Providence, RI	49.7
Washington, DC	63.9	Raleigh, NC	71.8	Columbia, SC	59.2
Dover, DE	61.9	Bismark, ND	51.0	Sioux Falls, SD	55.3
Wilmington, DE	59.6	Lincoln, NE	53.5	Chattanooga, TN	67.7
Miami, FL	75.0	Concord, NH	65.6	Knoxville, TN	55.0
Tallahassee, FL	76.7	Trenton, NJ	55.3	Memphis, TN	55.0
Atlanta, GA	62.0	Albuquerque, NM	76.2	Dallas, TX	68.3

Savannah, GA	68.1	Carson City, NV	58.0	Houston, TX	65.9
Honolulu, HI	76.8	Albany, NY	51.5	Salt Lake City, UT	70.5
Des Moines, IA	60.3	Bingamton, NY	59.9	Richmond, VA	59.1
Boise, ID	45.3	Buffalo, NY	49.2	Montpelier, VT	47.8
Chicago, IL	53.9	Long Island, NY	53.0	Seattle, WA	41.1
Indianapolis, IN	49.0	New York, NY	57.6	Green Bay, WI	44.7
Topeka, KS	59.0	Plattsburgh, NY	50.6	Milwaukee, WI	46.0
Louisville, KY	56.3	Potsdam, NY	48.5	Charleston, WV	62.8
New Orleans, LA	64.9	Poughkeepsie, NY	56.8	Cheyenne, WY	51.7
Source: HOTCALC Commercial Water Heating Performance Simulation Tool, Ver 1.0 1991					

Go back to

[Residential Heat Pump Water Heaters](#)